AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Signature Floorcoverings Pty Ltd

13 Wurundjeri Drive Epping VIC 3076 **Test Number** : 21-002324

 Issue Date
 :
 8/07/2021

 Print Date
 :
 8/07/2021

 Order Number :
 PO116023

11-05-2021

Sample Description Clients Ref : "Earth II Thermo Bak"

Tufted high and low loop pile carpet tile

End Use: Flooring

Nominal Composition: Solution Dyed Nylon Nominal Mass per Unit Area/Density: 580g/m2

Nominal Thickness: 6.5mm

AS ISO 9239.1-2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Radiant Heat Source

Date of Sample Arrival

Date Tested 07-07-2021

CHF Value	1	2	3	Mean	
Length	5.4	5.4	5.4	5.4	kW/m²
Width	5.4	-	-	-	kW/m²
HF-30 Value	1	2	3	Mean	
Length	5.4	5.4	5.4	5.4	kW/m²
Width	5.9	-	-	-	kW/m²
Smoke Value	1	2	3	Mean	
Length	217	178	192	196	%.min
Width	172	-	-	-	%.min

Melting

241887 51578 Page 1 of 2

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.





MICHAEL A. JACKSON B.Sc.(Hons)

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Signature Floorcoverings Pty Ltd

13 Wurundjeri Drive Epping VIC 3076 **Test Number** : 21-002324

 Issue Date
 :
 8/07/2021

 Print Date
 :
 8/07/2021

 Order Number :
 PO116023

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of $23\pm2^{\circ}$ C and relative humidity of $50\pm5\%$ for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

241887 51578 Page 2 of 2

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Fiona McDonald

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc.(Hons)